



# Outdoor Open Flame Devices



Outdoor Open Flame Devices or Appliances, including permanently installed or plumbed outdoor fireplaces, fire pits, BBQ's, pizza ovens and any other open flame outdoor device that are connected to a residential/commercial gas line service, at the discretion of the Fire Code Official shall be installed with the following:

- Gas shut-off valve located at stub out (at the building) and readily accessible.
- Timer device to regulate maximum operating time to three (3) hours.
- Ten (10) feet vertical & horizontal clearance to all combustibles measured from the center of the flame ring, not including the support structure. Devices per manufacturers installation guidelines that have less of a combustible clearance may be installed at the discretion of the Fire Official.
- 2nd accessible gas shut-off valve installed within 5' of the device.
- Two (2) feet maximum flame height.
- All parts/assemblies to be UL or ASME listed.
- Provide product specification sheet for device design.
- Surface supporting device system shall be of an ignition resistance material (approved by the California State Fire Marshal's office) extending minimum of two (2) feet around device.

(Truckee Fire Protection District of Nevada County, Ordinance 01-2016, Section 307.4.4)

The Town of Truckee Building Division will conduct inspections for residential outdoor open flame devices. The Truckee Fire Protection District will conduct nonresidential and residential inspections in Placer and Nevada County.

## For questions, please contact:

Truckee Fire Protection District  
(530) 582-7850  
[www.truckeefire.org](http://www.truckeefire.org)

Town of Truckee Building and Safety  
Division  
(530) 582-7821  
[www.townoftruckee.com](http://www.townoftruckee.com)